

ROCKY FLATS ENVIRONMENTAL TECHNOLOGY SITE REGULATORY CONTACT RECORD

Date: 09/13/96

Site Contact(s): Gary Guinn

Extension: X8043 / P4629

Regulatory Contact(s): Chris Gilbreath

Extension: 692-3371

Agency: CDPHE

Purpose of contact: RCRA Inspection of Building 889 Sumps

Thursday 9/12/96, after communicating with Randy Leitner of K-H, Gary Guinn of RMRS contacted Chris Gilbreath of CDPH&E concerning building 889 sumps and their inspection requirements. The sumps, part of the site waste processing system (unit 40), are interim status unit under RCRA and is part of the RFETS Tank Management Plan. The issue in question deals is the quarterly inspection due during this month and the current physical status of the unit. The sumps currently are covered with a steel cap to protect the sumps during the recent demolition of the above-ground structure. This cap prevents the unit from being inspected without a modification that would cost \$1-2 thousand dollars. The sump is currently empty with only a couple of nuts and a few rocks on the bottom. Also, the sump has been isolated to prevent future inputs. K-H is working the solution for this interim status unit and the solution should be coming in the near future.

Gary proposed that the observation of the project engineer completed just prior to capping the sumps be documented and an inspection report be filled out from that information. This would save the money for the modification to the cap. This was acceptable to Chris. Also discussed was a one or two month delay in the inspection as long as nothing was added to the sump. That was also acceptable.

Gary also brief Chris on the Proposed Guardhouses Project (B461 and B446) and The Proposed Acid Tanks Project (B219) for Decommissioning. Guardhouse only Issue is Lead-Based Paint.

Follow-up required (list any documents requested):

Document this action to Project Files.

DISTRIBUTION

FOR ENVIRONMENTAL CONTACTS:

<u>Fax</u>	<u>Name</u>	<u>Company</u>	<u>Building</u>
2865	T. R. Benton	WSI	T119B
3744	K. A. Holstein	DynCorp	T130D
N/A	G. R. Konwinski	RMRS	T130F
N/A	J. K. Wrapp	K-H	T130C
7553	W. M. Wierzbicki	SSOC	T130A
*3710	R. April	DOE, RFFO	116

ADDITIONAL DISTRIBUTION (add names as necessary/required):

<u>Fax</u>	<u>Name</u>	<u>Company</u>	<u>Building</u>
8244	M. E. Hickman	RMRS	T130F
N/A	P. R. Bengel	RMRS	T130F
N/A	D. C. Shelton	K-H	T130C

NOTE: Where recipients share FAX machines only one copy of this contact record will be transmitted.

ADMIN RECCRD

IA-A-000388